

  <p>PM SHRI केन्द्रीय विद्यालय संगठन</p>	<p>ಪಿಎಂ ಶ್ರೀ ಕೇಂದ್ರೀಯ ವಿದ್ಯಾಲಯ,ಟಿ.ಬಿ.ಡ್ಯಾಂ,ಹೊಸಪೇಟೆ पी एम श्री केन्द्रीय विद्यालय टी बी डेम होसपेट जिला-विजयनगर पिन कोड : 583225 फ़ोन नं. 08394-259587 PM SHRI KENDRIYA VIDYALAYA, T.B.DAM, HOSAPETE Distt. VIJAYANAGARA, KARNATAKA PIN: 583225 Phone 08394259587 (O) E-mail: kvhosapete@gmail.com :: CBSE AFFILIATION NO. 800031 KV CODE 1073 :: CBSE School Code: 49063 Website: https://hospet.kvs.ac.in</p>	  <p>आज़ादी का अमृत महोत्सव भारत 2023 INDIA</p>
F.130346(2)/2023-24/KVHPT		Date: 18-03-2024


Certificate


This is to certify that Vidyalaya is under process the compliance of all fire safety recommendation issued by the district fire officer, Ballari (Karnataka) for which we have taken permission to procure and install all the required items of fire safety in the Vidyalaya which is also attached with this letter. Which the Vidyalaya have to compliance within three months of the issue of the letter. We also undertake that we will submit the fire safety certificate as and when we received after completion of all process as we know it is mandatory compliance. We are fully responsible for all types of safety of students, employees and visitors.

Committee Members:

1. Mr. HARINATHA REDDY
2. Mr. S K PRAKASHA
3. Mrs. DEEPIKA PANDEY
4. Mrs. PREETI
5. Mr. NAGARAJA

TGT (P & HE)
TGT(ENGLISH)
PRT
TGT(LIBRARIAN)
SUB STAFF



 (M.L. Jeenger)
 ಪ್ರಾಂಶುಪಾಲರು / Principal
 ಕೇಂದ್ರೀಯ ವಿದ್ಯಾಲಯ ತುಂಗಭದ್ರಾ ಡ್ಯಾಂ ಹೊಸಪೇಟೆ
 केन्द्रीय विद्यालय तुंगभद्रा बाँद होसपेट
 Kendriya Vidyalaya, T.B.Dam, Hosapete.



ವಿವಿ ಶ್ರೀ ಕೇಂದ್ರೀಯ ವಿದ್ಯಾಲಯ,ಟಿ.ಬಿ.ಡ್ಯಾಂ,ಹೊಸಪೇಟೆ

पी एम श्री केन्द्रीय विद्यालय टी बी डेम होसपेट

जिला-विजयनगर पिन कोड : 583225 फ़ोन नं. 08394-259587

PM SHRI KENDRIYA VIDYALAYA, T.B.DAM, HOSAPETE

Distt. VIJAYANAGARA, KARNATAKA PIN: 583225 Phone
08394259587(O)

E-mail: kvhosapete@gmail.com ::CBSE AFFILIATION NO.
800031

KV CODE 1073 :: CBSE School Code: 49063

Website: <https://hospet.kvs.ac.in>



F.130112/2023-24/KVHPT/

Date: 14-03-2024

NOTESHEET

The CBSE Affiliation of PM SHRI Kendriya Vidyalaya Hosapete is being expired on 31.03.2024. So, we need to apply for the extension of the same. On CBSE SARAS Portal, the fire safety certificate is required mandatorily. Hence, we wrote a letter to the District Fire Officer for this certificate and after their survey report we got the fire safety recommendation letter which compliance to be done on urgent basis. Therefore, we need to purchase and install Hose Reel and Hose Pipe, fire extinguishers and all other required equipments of fire safety. So that we can get the fire safety certificate of the vidyalaya.

In this context, it is to be mentioned that due to urgency these items cannot be procured through GEM Portal as we have to get this certificate and apply for extension of CBSE Affiliation before 31.03.2024. Hence, you are requested to kindly approve the procurement and installation of these fire safety items from LPC Market Survey as per Rule-155 of GFR-2017. Further, it is also requested kindly approve the budget limit of rupees 3, 00,000/- in the fire equipment head of VVN for the session 2023-24.

The Committee Members are:

1. Sh N Harinath Reddy (TGT-P&HE)
2. Sh S K Prakash (TGT-English)
3. Mrs Deepika Bhatt(PRT)
4. Sh C Sreenivasulu (SSA)

Approved/Not Approved


Chairman

Vidyalaya Management Committee

PM SHRI KV Hospet

अध्यक्ष /मानवसंसाधन अधिकारी


Chairman / Manpower Chairman

कार्यवाही / VMC

केन्द्रीय विद्यालय /Kendriya Vidyalaya

तुंगभद्रा बाँध /Tunga Bhadra Dam

होसपेट /Hosapete - 583225 (K.A.)


14/03/2024
ಪ್ರಾಂಶುಪಾಲಕ / प्राचार्य / Principal
Manohar Lal Jeenger
ಕೇಂದ್ರೀಯ ವಿದ್ಯಾಲಯ ತುಂಗಭದ್ರಾ ಡ್ಯಾಂ ಹೊಸಪೇಟೆ
Principal
केन्द्रीय विद्यालय तुंगभद्रा बाँध होसपेट
Kendriya Vidyalaya, T.B.Dam, Hosapete.

ANNEXURE-1

(Up to 14.99 mtrs in height)

Group B, Educational Buildings

(These conditions are indicative and not exclusive all relevant provisions related to fire and life safety of NBC 2016 are mandatory.)

To

The Principal
PM SHRI Kendriya Vidyalaya
Tungabhadra Dam
Hosapet Taluk,
Vijayanagar Dist.Sub: Issue of Fire Safety recommendation to "PM SHRI Kendriya Vidyalaya" Located at
Tungabhadra Dam Hosapete, Hosapet Taluk, Vijayanagar Dist.

Ref: 01) Applicant Request Letter Dated: 01/03/2024.

02) No: 56/FSO/Hosapete/2024 Date: 07/03/2024

With reference-01 to the subject above cited, the premises of "PM SHRI Kendriya Vidyalaya" Located at Tungabhadra Dam Hosapete, Hosapet Taluk, Vijayanagar Dist was inspected by Fire Station Officer, Fire Station Hosapete on Dated 06/03/2024 & Submit the Report as per Reference-02 with respect to fire prevention, fire fighting and evacuation measures to be complied premises and Submitted building details as under.

A. Details of the Building/Premises:-

01.	Name and Address of the applicant.	:	The Principal PM SHRI Kendriya Vidyalaya Tungabhadra Dam Hosapet Taluk, Vijayanagar Dist.
02.	Name and Address of the premises.	:	PM SHRI Kendriya Vidyalaya Tungabhadra Dam Hosapet Taluk, Vijayanagar Dist.
03.	Name and Address of the Building owner.	:	The Principal Kendriya Vidyalaya Tungabhadra Dam Hosapet Taluk, Vijayanagar Dist.
04.	Number of Buildings	:	01 No Building
05.	Number of floors	:	Ground + 01 Upper floor
06.	Floor-wise details of occupancy		
	Ground Floor:	:	1) Class Rooms-06 Nos 2) Principle Room-01No 3) Hall Room-01No 4) Sports Room-01No 5) Staff Room-01 No 6) Office Room-01No
	First Floor	:	1) Class Rooms-04 Nos 2) Staff Room-01 No

			3) Library Room-01 4) Computer Room-01 5) Sanskrit Room-01 6) Maths lab-01 7) Physic Lab-01 8) SUP Room-01 9) Art Room-01 10) Science Room-01
07	Height of the building	:	07.70 mtrs
08	Site area	:	08.50 Acara
09	Built-up area of each floor :-		
	Ground Floor:	:	906.60 Sq Mtr
	First Floor	:	619.69 Sq Mtr
10	Total built-up area	:	1526.30 Sq Mtr
11	Surrounding properties:-		
	East	:	Open Ground
	West	:	Open Ground
	North	:	Staff Quarters
	South	:	Open Ground
12.	Set back area available around the Building:-		
	East	:	20.00 mtrs
	West	:	05.00 mtrs
	North	:	10.00 mtrs
	South	:	10.00 mtrs
			Recommended: To provide as per Local Zonal Regulations.

B. On inspection of this Educational premises, the following fire prevention, fire fighting and evacuation measures are recommended & are considered absolutely essential from fire safety point of view:-

Sl. No. [01]	Details [02]	Existing [03]	Recommendations [04]																								
01	Accessibility to Premises.	The premises is accessible From 12 Mtrs Wide TB Dam road Road At South side.	--																								
02	No of entrances.	01 No	--																								
03	No. of staircases available.	<table border="1"> <tr> <td>No of staircase</td> <td>:</td> <td colspan="2">02 No's</td> </tr> <tr> <td>Width of staircase</td> <td>:</td> <td>01.50 mtrs</td> <td>01.50 mtrs</td> </tr> <tr> <td>Width of treads</td> <td>:</td> <td>30 cms</td> <td>30 cms</td> </tr> <tr> <td>Height of risers</td> <td>:</td> <td>15 cms</td> <td>15 cms</td> </tr> <tr> <td>No of riser per flight</td> <td>:</td> <td>10 riser</td> <td>10 riser</td> </tr> <tr> <td>Height of handrail</td> <td>:</td> <td>01.00 mtrs</td> <td>01.00 mtrs</td> </tr> </table>	No of staircase	:	02 No's		Width of staircase	:	01.50 mtrs	01.50 mtrs	Width of treads	:	30 cms	30 cms	Height of risers	:	15 cms	15 cms	No of riser per flight	:	10 riser	10 riser	Height of handrail	:	01.00 mtrs	01.00 mtrs	--
No of staircase	:	02 No's																									
Width of staircase	:	01.50 mtrs	01.50 mtrs																								
Width of treads	:	30 cms	30 cms																								
Height of risers	:	15 cms	15 cms																								
No of riser per flight	:	10 riser	10 riser																								
Height of handrail	:	01.00 mtrs	01.00 mtrs																								
04	Fire extinguisher	01) Provided 10 No's of 04 Kg capacity ABC FE.	01) 01 No ABC Fire Extinguisher each of 6																								

		<p>02) Provided 06 No's of sand Bucket</p> <p>03) Provided Two number of Hand gloves</p>	<p>kg capacity Should be Located As Available Within 15 Mtrs Radius. In each floor.</p> <p>02) 01 No of CO2 Fire Extinguisher of 4.5 kg capacity Should be Provided near each Electrical Panel Board And Electrical Room. Switch board.</p> <p>03) 01 Mechanical Foam Extinguishers of 09 ltrs Capacity and 01 ABC type Extinguishers of 6 kg capacity should be provided near diesel Generator.</p> <p>04) 01 DCP Extinguishers of 4 kgs capacity Should be provided in the Kitchen If Provided for th purpose of mid day meal.</p> <p>[All the extinguishers suggested above should be with B.I.S. markings and should be located at an easly accessible position without obstructing the normal passage and maintained periodically].</p>
05	Hose reel hose system.	Not Installed	<p>Recommended to Provide One Hose Reel Hose Near The Staircase (One Hose Reel Hose System For Every 1000 Sq. Mtr) The Hose Reel hose of Min 19 mm Size And 30 mtr length Shall be Provided to Reach the Farthest Point Of Each Floor And shut off branch having a nozzle of 5 mm size. The hose reel hose has been connected at each landing.</p>
06	At the terrace tank level with minimum pressure of 3.5 kg/cm ²	Not Installed	<p>To Provide 01 No pump with minimum pressure of 450 LPM.</p>
07	Diesel generators.	Provided 01 No. of 30 KVA Diesel Generator	<p>It should be connected to alternate power supply in case Failure of Electricity.</p>
08	Terrace tank.	Provided 02 No's 10000 Ltrs Capacity Syntax tank for Domestic Purpose.	<p>To Provide Over Head Tank of 10,000 Ltrs for Fire Fighting purpose to be connected to Hose reel hose system.</p>
09	Escape routes	-	<p>Signage board is required with illuminated points for in which direction to go outside from the building for staff & students and also separate light arrangement to the illumination board by doing from battery operated</p>
10	Fire order (Fire Safety Plans)	Displayed	<p>The Notice board have been indicted the action should be taken by the employees in case of any emergency should be displayed with the telephone number of hospet Fire Station i.e-</p>

			08394-230555 & 101, and the telephone number of nearest Ambulance services and Police Station.
11	No Smoking Board	Displayed COTPA Sec-4 Direction No Smoking area Smoking hear is an offence Board Should be written in English & Kannada both language Shall be Prominently displayed at inside the Entry/Exist of Each Floor.	Adequate
12	Fire Siren	Not Installed	A fire Siren shall be installed in the premises to Inform the inmates in case of a fire emergency/evacuate the area
13	Nominate one fire Nodal officer	.	A fire nodal officer shall be nominated either from teaching or no teaching staff.
14	Fire fighting training.	Not Imparted	At-least 40% of School Staff should be got trained in basic fire fighting at R.A.Mundkur fire & Emergency Services Academy, Bannerughatta road, Bangalore within 3 months or at an early date.

15) Fire Precautionary Measures:

- 1) Explosive and flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory and electrical cum panel premises.
- 2) Accumulation of combustible waste in and around the premises should be avoided.
- 3) The exit ways shall be always kept clear without any Obstruction.
- 4) Liquefied petroleum gas should not be stored in the building.
- 5) The doors shall not be kept locked / latched during working hours and shall be free from obstruction.
- 6) During the class hours the class room doors shall not be locked from inside to outside.
- 7) As per Honorable supreme court order all teachers and staffs shall be trained to handle safety equipment, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the fire safety day on 14th of every year by conducting fire safety drills with co-ordinate with fire service department.


Hence this "Fire Safety recommendation" is issued to "PM SHRI Kendriya Vidyalaya" Located at Tungabhadra Dam Hosapete, Hosapete Taluk, Vijayanagar Dist subject to strict adherence of the conditions as laid down in this Recommendations and to check the portable fire extinguisher & Hose reel hose, and to conduct drills periodically and the Management must not extend the height of the building beyond 15.0 meters. Subject to condition and compliance of the above recommendations in column-4 of serial-B within 3 months and compliance to undersigned.

The "Fire Safety recommendation" is valid for only one year from the date of issue.

Date- 13-03-2024
Place- Ballari.

Copy to: FSO Hosapete

Yours faithfully,



District Fire Officer
Karnataka State Fire & Emergency Service
Ballari District, Ballari.